

AFTER TREATMENT BEFORE DISTRIBUTION
 SAMPLES COLLECTED IN 2005
 EXCEPT WHERE INDICATED

PORTLAND WATER DISTRICT
SUPPLEMENTARY INFORMATION
TO 2008 CHEMICAL ANALYSIS

CONTAMINANT	MCL ¹ (MG/L)		GREATER PORTLAND	STEEP FALLS
ORGANIC				
=====				
VOLATILE ORGANICS				

BENZENE	0.005		<0.0005	<0.0005
CARBON TETRACHLORIDE	0.005		<0.001	<0.001
1,4-DICHLOROBENZENE	0.075		<0.0005	<0.0005
1,2-DICHLOROETHANE	0.005		<0.0005	<0.0005
1,1-DICHLOROETHENE	0.007		<0.0005	<0.0005
1,1,1-TRICHLOROETHANE	0.2		<0.0005	<0.0005
TRICHLOROETHENE	0.005		<0.0005	<0.0005
VINYL CHLORIDE	0.002		<0.0005	<0.0005
METHYL TERT-BUTYL ETHER (State req.)	0.035		<0.001	<0.001
1,2-DICHLOROBENZENE	0.6		<0.0005	<0.0005
cis-1,2-DICHLOROETHENE	0.07		<0.0005	<0.0005
trans-1,2-DICHLOROETHENE	0.1		<0.0005	<0.0005
1,2-DICHLOROPROPANE	0.005		<0.0005	<0.0005
ETHYLBENZENE	0.7		<0.0005	<0.0005
CHLOROBENZENE	0.1		<0.0005	<0.0005
STYRENE	0.1		<0.0005	<0.0005
TETRACHLOROETHENE	0.005		<0.0005	<0.0005
TOLUENE	0.1		<0.0005	<0.0005
o-XYLENE			<0.0005	<0.0005
DICHLOROMETHANE	0.005		<0.0001	<0.0001
1,2,4-TRICHLOROBENZENE	0.07		<0.0005	<0.0005
1,1,2-TRICHLOROETHANE	0.005		<0.0005	<0.0005
1,2-DIBROMO-3-CHLOROPROPANE	0.2		<0.001	<0.001
OTHER SYNTHETIC ORGANICS				

BENZO(A)PYRENE	0.0002		0.0	<0.0002
BIS (2-ETHYLHEXYL) ADIPATE	0.4		0.0002	<0.002
BIS (2-ETHYLHEXYL) PHTHALATE	0.006		0.0002	<0.002
HEXACHLOROBENZENE	0.001		<0.0002	<0.0002
HEXACHLOROCYCLOPENTADIENE	0.05		<0.005	<0.005
2,3,7,8-TCDD DIOXIN	0.00000003		STWV ²	
PESTICIDES/PCB'S				

ALACHLOR			<0.0005	<0.0005
ALDICARB			<0.003	<0.002
ALDICARB SULFONE			<0.002	<0.002
ALDICARB SULFOXIDE			<0.002	<0.002
ATRAZINE			<0.0005	<0.0005
OXAMYL	0.2		<0.002	<0.002
CARBOFURAN	0.04		<0.002	<0.002

AFTER TREATMENT BEFORE DISTRIBUTION
 SAMPLES COLLECTED IN 2005
 EXCEPT WHERE INDICATED

PORTLAND WATER DISTRICT
SUPPLEMENTARY INFORMATION
TO 2008 CHEMICAL ANALYSIS

CONTAMINANT	MCL ¹ (MG/L)		GREATER PORTLAND	STEEP FALLS
PESTICIDES/PCB'S cont.				

CHLORDANE	0.002		<0.00025	<0.00025
2,4-D	0.07		<0.004	<0.004
HEPTACHLOR	0.0004		<0.0002	<0.0002
HEPTACHLOR EPOXIDE	0.0002		<0.0002	<0.0002
LINDANE	0.0002		<0.0002	<0.0002
METHOXYCHLOR	0.04		<0.0005	<0.0005
PCB'S AS(DECACHLOROBIPHENYL)	0.0005		ND ³	<0.0002
PENTACHLOROPHENOL	0.001		<0.0002	<0.0002
TOXAPHENE	0.003		<0.0015	<0.0015
2,4,5 TP (SILVEX)	0.05		<0.0005	<0.0005
HERBICIDES/PESTICIDES				

DALAPON	0.2		<0.003	<0.003
DINOSEB	0.007		<0.0008	<0.0008
DIQUAT (1993)	0.02		<0.00008	<0.00008
ENDOTHALL (1993)	0.1		<0.0005	<0.0005
ENDRIN	0.002		<0.0002	<0.0002
GLYPHOSPHATE	0.7		STWV	
PICLORAM	0.5		<0.004	<0.004
SIMAZINE	0.004		<0.0002	<0.0002
FOOTNOTES	<p>¹MCL- Maximum Contaminant Level, The highest level of a contaminant allowed or recommended in drinking water.</p> <p>²STWV-State waiver</p> <p>³ND = None Detected</p>			