



**Portland Water District**  
*FROM SEBAGO LAKE TO CASCO BAY*

**Barron Center Water Main Replacement RFB**

**ADDENDUM NUMBER ONE**

Prepared By:  
Patrick Fitzgerald, Purchasing  
Portland Water District  
225 Douglass Street  
PO Box 3553  
Portland, ME 04104-3553

Addendum Date: 3/3/22

**225 Douglass Street**  
**Phone: 207.774-5961**

**P.O. Box 3553**  
**Fax: 207.761-8329**

**Portland, Maine 04104-3553**  
**Web: [www.pwd.org](http://www.pwd.org)**

**AMEND THE RFB AS FOLLOWS:**

**SPECIFICATIONS:**

(Item 1 of 2) – Section 00020 – Invitation to Bid , Add the following after paragraph 6:

*If the Contractor provides documentation on material delays that prohibit 2022 completion, the contract substantial completion date will be increased to July 1, 2023 through a change order.*

(Item 1 of 1) - Section 01250 – Measurement and Payment Page 130, 2.01 B - Basis of Payment Delete entire paragraph. Replace with :

*Payment of the unit price established in the Bid shall be full compensation for installation and maintenance of temporary water systems, equipment, excavating, shoring and bracing, dewatering, pipe & gaskets, laying and jointing, connections to existing piping, removal and disposal of existing piping, capping pipes that are not removed, thrust restraint, select backfill, base and subbase gravels, rip rap, backfilling, testing, restoration, traffic control, flagging and associated work as specified and shown on the Drawings.*

**QUESTIONS:**

Q: Are we going to have to enter MTA property for this project? If so are there any special requirement from the MTA to do so?

A: *The Contractor will have to enter MTA property. Access to the MTA property will be through the Barron's Center parking lot only, not the north bound off ramp. PWD will notify MTA prior to the project start.*

Q: Would you please verify the location of the 2 6" cut-in valves?

A: *There is one on Holm Ave and one 150' west of Holm Ave (shown on the plans).*

Q: Also does the District have any more information regarding the ledge?

A: *No.*

Q: How was the quantity of 225 cy of rock removal arrived at?

A: *This is an estimate based on length only.*

Q: Are we going to be able to close the roads to local traffic for the water main installation if the detour is properly signed?

A: *Detours will have to be approved by the City as part of the Contractor's street opening permit and traffic control plan submission.*

Q: Would the District please consider extending the bid date by 1 week to 3/29/2022?

A: *Unfortunately, no, the due date cannot be changed.*

Q: Do you have the depth of the existing water main that we are replacing?

A: *We do not.*

**PLEASE SIGN AND SUBMIT WITH BID**

Submitting Firm Name	Address
By	Title
Signature of Person Bidding	