



Portland Water District
FROM SEBAGO LAKE TO CASCO BAY

**Falmouth Rd
Water Main Replacement**

ADDENDUM NUMBER ONE

Prepared By:
Patrick Fitzgerald
Portland Water District
225 Douglass Street
PO Box 3553
Portland, ME 04104-3553

Addendum Date: 4/12/22

QUESTIONS AND RESPONSES:

Q: Do you guys expect ledge here? If encountered, how will it be paid as there is no bid item for it?

A: The pipe in ledge detail is a standard detail. There is no item for ledge as there was no ledge on previous installations. In the event a section of ledge was encountered, it would be paid for either through a change order or hourly rates.

Q: What are type of the pipes to be installed on the project?

A: PVC and ductile iron.

Q: Are there any portions of the project that will need to be Bored?

A: No.

Q: Are the crossings to be Jack & Bored or Directionally Bored?

A: No.

Q: What are the approximate lengths and diameters of the portions to be bored?

A: N/A.

Q: How much is the cost estimate of the project?

A: \$825,000.

Q: Can you also confirm the 8" ductile iron item (bid item 04) is for the tie in work to the 20" line? If that is not the case, please verify.

A: It is for the tie in work to the 20" line.