



**Portland Water District**  
*FROM SEBAGO LAKE TO CASCO BAY*

**Concord St.  
Water Main Replacement**

**ADDENDUM NO. 1**

**CONTRACT REQUIREMENTS AND SPECIFICATIONS**

DATE: AUGUST 3RD, 2021

Prepared By:  
Patrick Fitzgerald, Purchasing  
PORTLAND WATER DISTRICT  
225 Douglass Street  
Portland, ME 04104

Portland Water District  
Portland, Maine

Concord St.  
Water Main Replacement

**ADDENDUM NO. 1**

August 3rd, 2021

General

The Portland Water District has received the following question from an interested party and is addressing the question as noted:

1. Question: Can we do conventional excavation & backfill with 8" PVC SDR 35 instead of 8" HDPE?

Answer:

The PWD contacted the COP for the question and received the following answer: No, the COP will not accept conventional excavation & backfill with 8" PVC SDR 35.

Please bid the pipe as specified in the documents.

Coordination of re-connection with the sewer laterals is integral to the coordinated efforts and planning between the general contractor and pipe lining specialist as indicated in the specifications.